


# Certificate Of Conformity

## Electromagnetic Compatibility (EMC)

A sample of this product has been subject to assessment by Nemko, and is hereby confirmed to be in conformity with the applicable European EMC standards referred below. Sufficient evidence of conformity with the EMC Directive (2014/30/EU) has been provided.

Certificate No.: **HFC 180504**

Applicant	<b>LEDVANCE GmbH</b> SteinerneFurt 62, 86167 Augsburg, Germany
Manufacturer	<b>LEDVANCE GmbH</b> SteinerneFurt 62, 86167 Augsburg, Germany
Product	<b>Emergency Lighting Luminaire</b>
Model	<b>EM DL DN120 MT 3H ANTIPANIC, EM DL DN120 MT 3H ESCAPE, EM DL DN120 HO AT 3H ANTIPANIC, EM DL DN120 HO AT 3H ESCAPE</b>
Rating	<b>Charging mode: 4 W 220-240 VAC 50/60 Hz Discharging mode: 1300 / 1800 mAh, 7.2 V d.c. Ni-MH, Cl. II</b>
Additional information	<b>See page 2</b>
Brand Name	 <b>LEDVANCE</b>
Documentation	<b>EMC test report No. : 351063</b>
Standards applied	<b>EN 55015:2013+A1:2015 EN 61547:2009 EN 61000-3-2:2014 EN 61000-3-3:2013</b>
This certificate is valid until	<b>2018-5-14 + 48 months</b> <small>(provided that all signed certification conditions are complied with, and that possible changes to the product are notified to Nemko for acceptance prior to implementation)</small>
Nemko order number	<b>351063</b>

www.nemko.com

This certificate authorizes the manufacturer to affix the below shown Nemko EMC Mark to each conforming product. And provided it is otherwise confirmed that the product also conforms with any other applicable Directives, the manufacturer (or the European authorized representative) may prepare an EC/EEA Declaration of Conformity and affix the below shown CE-marking to each conforming product.

Date of issue **2018-5-14**

Certificate revision: None

*Zone Peng*

Zone Peng



### Annex I (Related models)

Model name	Ratings and characteristics
EM DL DN120 MT 3H ANTIPANIC	Maintained self-contained emergency luminaire, Manual test, 235lm, 4 W 220-240 V 50 Hz, 7.2 V 1300 mAh Ni-MH, 3 h duration, ta = 0-40 °C
EM DL DN120 MT 3H ESCAPE	Maintained self-contained emergency luminaire, Manual test, 235lm, 4 W 220-240 V 50 Hz, 7.2 V 1300 mAh Ni-MH, 3 h duration, ta = 0-40 °C
EM DL DN120 HO AT 3H ANTIPANIC	Non-Maintained self-contained emergency luminaire, Automatic test, 335lm, 4 W 220-240 V 50 Hz, 7.2V 1800 mAh Ni-MH, 3 h duration, ta = 0-40 °C
EM DL DN120 HO AT 3H ESCAPE	Non-Maintained self-contained emergency luminaire, Automatic test, 335lm, 4 W 220-240 V 50 Hz, 7.2 V 1800 mAh Ni-MH, 3 h duration, ta = 0-40 °C

Note: All these models can be equipped with two kinds of LED module, the type name of LED module are 3030 and 2835.